

Product Safety Information

Ventilation attachment for tall cabinets asecos, with exhaust air monitoring, w./o. alarm, W 200 x D 400 x H 200 mm

Manufacturer/Responsible Person: asecos GmbH, Weiherfeldsiedlung 16-18, 63584 Gründau, Deutschland

E-Mail: info@asecos.com

Please note the technical data of the products!

Article Numbers: 138915, 138914

Safety Instructions:

- Read the operating instructions carefully before installation and only install in accordance with the instructions.
- The appliance must be connected to a suitable power supply. Incorrect connection can lead to a risk of electric shock; disconnect the appliance from the mains immediately in the event of a fault.
- If the appliance is visibly damaged, it must not be put into operation
- Only use the appliance with the intended exhaust air connection. Ensure that the vent opening is not blocked. Carry out regular checks of the exhaust air monitoring and alarm function.
- Pay attention to the indicator lights: Green indicator light in normal operation, red indicator light in the event of a fault
- Risk of suffocation due to improper use during installation or use.
- Do not use the appliance in EX zones, only operate it outside the EX zone.
- Do not use in conductive environments to avoid the risk of electric shock.
- Please remember that children and vulnerable persons should be kept away from appliances.