

Product Safety Information

Mobile filling station CEMO DT-Mobil Easy 200 I with ADR approval, W 800 x D 620 x H 610 mm

Manufacturer/Responsible Person: CEMO GmbH, In den Backenländern 5, 71384 Weinstadt, Deutschland

E-Mail: kontakt@cemo-group.com

Please note the technical data of the products!

Article Numbers: 139502, 139501, 139500, 139499

Safety Instructions:

- Caution: There is a risk of explosion due to improper handling of flammable liquids. Risk of suffocation due to improper handling of fuels or petrol station contents. Fire hazard due to leaks when refuelling or handling diesel fuel.
- Safety advice: Wear suitable protective equipment when refuelling. Explicated hazard due to vapours.
- Warning: Only authorised for transporting diesel fuel. Only use the hose and nozzle for diesel fuel; other liquids could be dangerous.
- Note: The filler neck must be properly secured to prevent overflow.
- Instructions: Check for leaks before each use and do not use if there are any abnormalities.
- Information: Regular inspections in accordance with ADR regulations are required. Periodic inspection of the petrol station every 2.5 years is required.
- Caution: Do not bring electrical components into contact with water to avoid the risk of electric shock.
- Observe safety precautions: The electric pump is only suitable for the specified voltage range of 12 V. The electric pump may only be installed by qualified personnel.
- Ensure correct handling of hazardous substances to avoid health risks. Avoid skin contact with fuels and chemicals.
- In the event of a spill or leak, take immediate action to prevent environmental damage.
- The mobile petrol station is only approved for commercial use; not recommended for private use. The mobile petrol station is not suitable for use in residential areas.
- Only operate outdoors and with adequate ventilation. Ensure correct ventilation during filling to avoid overpressurisation.
- Ensure that the tank is only filled with authorised fuels.
- Regular maintenance and inspection of equipment in accordance with ADR regulations.
- Only hold hose retractions in an upright position.
- Risk of injury due to improper handling or transport of the mobile petrol station.