

Product Safety Information

Compressed gas cylinder cabinet G-ULTIMATE-90 Standard, hinged door stop left/right, W 598 x D 615 x H 2050 mm

Manufacturer/Responsible Person: asecos GmbH, Weiherfeldsiedlung 16-18, 63584 Gründau, Deutschland

E-Mail: info@asecos.com

Please note the technical data of the products!

Article Numbers: 463355, 463353

Safety Instructions:

- Risk of suffocation if the gas cylinders are stored incorrectly. Risk of explosion if the cylinders are handled incorrectly or damaged.
- Safety precautions must be observed when handling pressurised gas cylinders and caution must be exercised when storing pressurised gas cylinders and hazardous substances.
- Avoid access to fire, open flames and flammable materials in the vicinity of the cabinet.
- Regularly check the ventilation system and carry out maintenance and inspection of the cylinders and the cabinet.
- Intended for indoor use only.
- Ensure that the bottles are properly secured to prevent them from accidentally falling over.
- Allow access to the cabinet only to authorised personnel and always lock the hinged door securely to prevent unauthorised access.
- In the event of a leak, evacuate immediately and call a specialist.