

Product Safety Information

Compressed gas cylinder cabinet G-OD Standard, double wing door, fixed or hinged glass cut-out, various sizes. Sizes

Manufacturer/Responsible Person: asecos GmbH, Weiherfeldsiedlung 16-18, 63584 Gründau, Deutschland

E-Mail: info@asecos.com

Please note the technical data of the products!

Article Numbers: 463415, 463414, 463413, 463412, 463408, 463407

Safety Instructions:

- Set up securely: The bottle cabinet must be placed on a stable, level surface to prevent it from tipping over.
- Only use for the gas cylinders specified in the operating instructions.
- Only use outdoors to avoid overheating or damage caused by the weather.
- Ensure placement in a well-ventilated area.
- Do not expose the product to direct sunlight or extreme temperatures.
- In the event of damage or leaks, initiate suitable emergency measures immediately and inform the relevant safety authorities.
- Carry out regular inspection and maintenance of the cabinet to ensure safety.
- Do not overfill the cupboard or fill it with other materials.
- Set up out of the reach of children to prevent unauthorised access.
- Only use suitable and approved material for storage.
- Take care when handling pressurised gas cylinders: observe safety precautions and use PPE.
- Ensure that the bottle holders and tensioning straps are correctly installed to prevent the bottles from falling over.
- Fire hazards: Keep the cabinet away from fire and heat sources, Brand- und Explosionsgefahr.
- Risk of suffocation due to insufficient ventilation: Do not install the cabinet in closed rooms without ventilation.
- Observe hygiene: Keep the interior surfaces clean and free from dirt.
- Avoidance of impacts: The cabinet should be positioned in such a way that no impacts with other devices are to be expected.
- Read the operating instructions carefully before use.
- Of course, improper handling can lead to explosions.